

To: DAgostino, Daniel[DAgostino.Daniel@epa.gov]
From: Rasso, Mark
Sent: Thur 5/3/2018 3:46:02 PM
Subject: RE: Newark Sampling

The LCR requires Newark to keep sampling every six months until they qualify for reduced monitoring. The only exception would be if they were a (b)(3) system since 1992 and only now exceeded, which would mean they are required to put in treatment and would not have to monitor until they were done.

From: DAgostino, Daniel
Sent: Wednesday, May 02, 2018 3:56 PM
To: Rasso, Mark <Rasso.Mark@epa.gov>
Subject: Newark Sampling

Hi Mark,

Got any info on when they can sample again?

Dan



Daniel J. D'Agostino
Drinking Water and Groundwater Protection Section
Clean Water Division | US Environmental Protection Agency, Region 2
212-637-3805 | DAgostino.Daniel@epa.gov